

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Memo/School/25-26/027

Dated: 23/07/2025

It is certified that an inspection team headed by Kamlesh Singh (C.A.E.) with team

(Name of Officers with designation) from U.P. Jal Niyam (Rural) Ghazipur PHED inspected the

SRS International School, Bareilly, Zamania, Ghazipur (Name & Address of the

school) on 23/07/2025 (date of inspection) and on the basis of Water Test Report (Attached)

bearing noRWLT/SNL/0366/2025-26 dated 21/07/2025 of

Regional Water Analysis Laboratory, Uttar Pradesh Jal Niyam

Bhagwanpur, Varanasi - UP (PHED Lab) certified

that the SRS International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till One Year

Signature with Seal: प्रभाती चिकित्साधिकारी

Name : प्रभाती चिकित्साधिकारी

Designation : प्रभाती चिकित्साधिकारी

Name & Address of the Office / Department : प्रभाती चिकित्साधिकारी

To The Manager  
SRS International School Zamania  
(Name & Address of the Institution) Ghazipur

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



REGIONAL WATER ANALYSIS LABORATORY, UTTAR PRADESH JAL NIGAM  
Bhagwanpur, Varanasi – Uttar Pradesh 221005  
Email: - [jalnigamvns@gmail.com](mailto:jalnigamvns@gmail.com).



**\* TEST REPORT \***

<b>Name &amp; Address of Customer:</b> <b>SRS INTERNATIONAL SCHOOL, BARESAR, ZAMANIYA, GHAZIPUR, U.P.</b>			<b>Customer Reference No.</b>		<b>No: 366/sk/29 Dated: 21/07/2025</b>	
			<b>Sample Submitted by</b>		<b>Mr. UJJWAL KUMAR SINGH</b>	
			<b>Date of Sample Receipt</b>		<b>21/07/2025</b>	
			<b>Analysis Starting Date</b>		<b>21/07/2025</b>	
			<b>Analysis completion Date</b>		<b>21/07/2025</b>	
<b>Discipline: Chemical Testing</b>			<b>Group: Water</b>			
<b>Test Report No.:</b>		<b>RWTL/SNG/0366/2025-26</b>	<b>Date of Issue:</b>		<b>21/07/2025</b>	
<b>Registration no.:</b>		<b>RWTL/SNG/366/REG2526</b>	<b>Condition of Sample:</b>		<b>Unsealed</b>	
<b>Source:</b>		<b>NA</b>	<b>Quantity/Type of Bottle:</b>		<b>1000ml / Amber Colored Glass Bottle</b>	
<b>Scheme:</b>		<b>NA</b>	<b>Location/Depth:</b>		<b>RO plant SRS INTERNATIONAL SCHOOL, BARESAR, ZAMANIYA, GHAZIPUR, U.P.</b>	
<b>Village:</b>		<b>BARESAR</b>	<b>Habitation:</b>		<b>NA</b>	
<b>Block: -</b>		<b>ZAMANIYA</b>	<b>District:</b>		<b>GHAZIPUR</b>	
<b>Latitude:</b>		<b>NA</b>	<b>Longitude:</b>		<b>NA</b>	
<b>Sample Type: Treated Water</b>						
Sr. No	Parameter	Result	As per 15-10500:2012 (2nd Rev.)		Unit	Reference Method:
			Acceptable Limit	Permissible Limit		
1	pFI	7.77	6.5-8.5	No Relaxation		IS 3025 (Part 11-1993) Electrometric Method
2	Colour	01	5	15	Hazen	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Disagreeable		IS 3025 (Part 5 -2018) (Second Revision)
4	TDS	282	500	"2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	0.18	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	11	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	122	200	600	mg/l	I63025 (Pan 21- 2019) EDTA Method
8	Calcium	29	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	15	30	100	m\$/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	86	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition:

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed)
5. \* Value not available or test not performed for this parameter.

Dr. Shweta Pal  
Quality Manager  
Authorized Signatory  
For, Regional Water Analysis,  
Laboratory Jal Nigam Varanasi – UP.

End of the Test Report